LGAI Technological Center, S.A. (APPLUS) Campus UAB - Ronda de la Font del Carme s/n 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.applus.com





CERTIFICATE



No

0370-CPR-3927

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

POWER, CONTROL AND COMMUNICATION CABLES. CABLES FOR GENERAL APPLICATIONS IN CONSTRUCTION WORKS SUBJECT TO REACTION TO FIRE REQUIREMENTS.

FAMILY: AUDIOCABLE CLASSIFICATION: Cca-s1b,d1,a1

Place on the market under the name of:

PVS NV

VELDSTRAAT 99 3500 HASSELT (BELGIUM)

And produced in the manufacturing plant:

19/32301715

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 50575:2014, EN 50575:2014/A1:2016

under system 1+ are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 20th March 2020 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The monitoring assessment will be done before December 2020

Bellaterra, 20th March 2020

LGAI Technological Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with the number of certificate.

You can check the validity of this certificate into our website at: https://apps.applus.com/microsites/microsites/FECIP/login



LGAI Technological Center, S.A. (APPLUS) Campus UAB s/n – Ronda de la Font del Carme, s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.appluslaboratories.com



Technical Annex Ed. 1 20/03/2019

0370-CPR-3927

DESIGNATION	AUDIOCABLE
REACTION TO FIRE CLASS	Cca-s1b,d1,a1

CROSS SECTIONAL RANGE	RATED VOLTAGE
Conductor of 0,2mm ² (number of conductors: 2,4) Conductor of 0,34mm ² (number of conductors: 2,4)	300/500 V